

Instructions for after a System Pressure Advisory has been lifted

Customers are advised to "flush" their water lines following the lifting of a boil water advisory in order to clear plumbing of potentially contaminated water. Flushing your household and building water lines includes interior and exterior faucets, showers, water and ice dispensers, water treatment units, etc. Please use the following guidance:

Cold Water Faucets:

Before using the water line for drinking, brushing teeth, making ice cubes, food preparation etc., make sure it is clear from any forms of particulate matter and air (milky coloration). Turn on the cold water tap and let it run until water becomes clear. You should also open all cold-water lines such as fountains, showers and outside water spigots and run them for five to ten minutes.

Hot Water Faucets:

To clear hot-water pipes and water heater, flush the hot water line for a minimum of 15 minutes for a typical household 40-gallon hot-water tank, 30 minutes for an 80-gallon hot water tank or larger. Hot water should be clear of sediment and air before using to wash hands and for hand-washing of dishes, pots and pans, etc.

Dishwashers:

After flushing hot water pipes and water heater, run dishwasher empty one time.

Coffee Makers, Food Dispensers and Beverage Machines:

Flush equipment like food dispensers and beverage machines with clean water and follow the instruction manual on how to disinfect or clean the machine.

Water Treatment Device:

Replace water filters, water cartridges, faucet screens and aerators on all taps used as water treatment and filtration devices, in accordance with manufacturer recommendations. When in doubt, it is always best to clean, sanitize and disinfect any of these devices before using water again.

After a System Pressure Advisory

FAQ



Humidifiers:

Discard any water used in humidifiers, Continuous Positive Airway Pressure (CPAP), oral, medical, or health care devices, and rinse the device with clean water, in accordance with manufacturer recommendations.

Refrigerator Water-Dispensing Machine:

Water dispensers from refrigerators should be flushed with at least one quart of water. If unsure of your dispenser's capacity, refer to manufacturer specifications.

Ice Cubes:

Automatic ice dispensers should be emptied of ice made during the system pressure advisory and run through a 24-hour cycle, discarding the ice to assure purging of the icemaker water supply line.

Due to the flushing of the lines by residents and the flushing of the hydrants, some customers may experience a lack of water pressure and/or discolored water. However, this is an expected result and does not pose an immediate health risk. Please contact us if you have any questions.

Questions may be directed to Hendersonville Water and Sewer at (828) 697-3073 Monday-Friday 8am-5pm. Issues occurring outside of regular business hours can be reported to the after-hours number at (828) 891-7779.